



Roxeler Baustoffprüfstelle

Baustoffprüfung
Baugrundgutachten
Bauwerkserhaltung

Roxeler Ingenieurgesellschaft mbH
Otto-Hahn-Straße 7 · 48161 Münster

Vario Baustoffsysteme GmbH
Dielinger Straße 60

32351 Stemwede

Bauaufsichtlich anerkannte
Prüf-, Überwachungs- und Zertifizierungsstelle (PÜZ)

Notifizierte Zertifizierungsstelle gemäß
Verordnung (EU) Nr. 305/2011

Privatrechtlich anerkannte Prüfstelle nach RAP Stra
für bituminöse und mineralische Baustoffe

Durch die DAkkS nach DIN EN ISO/IEC 17025
akkreditierte Prüfstelle.

Die Akkreditierung gilt für die in der
Urkunde aufgeführten Prüfverfahren
am Standort Münster.



Test of water penetration depth in accordance with DIN EN 12390-8

Test certificate no. : 040068-09 38425

Information of the applicant

Building measure:

Element

Type of test

Supplier:

Vario Baustoffsysteme GmbH
(Stemwede)

Number of cubes: 1

Type of concrete:

C35/45

Manufacturing day: 12.05.2009

Strength class:

C35/45

Information of test centre

Delivery on:

Storage: dry


Test on: 24.08.2009

At the age of: 104 days

Designation	Dimensions			Weight	Bulk density	max. water pen. depth
	a	b	h			
Einlegeschild	mm	mm	mm	kg	kg/m ³	mm
WP 1	200,0	200,0	120,0	--	--	--
Average:						

Remarks: The test was accomplished for 3 days at water pressure of 1 bar. No water effuse noted from concrete or "TBT Fire Stop Tunnel"

Münster, 15.01.2016



Head of testing centre

The test report may only be duplicated in full. Shortened copies or copies in extract must be authorised in writing by the material testing centre.

Roxeler Ingenieurges. mbH
Baustoffprüfstelle
Otto-Hahn-Straße 7
D-48161 Münster

Telefon (0 25 34) 62 00-0
Telefax (0 25 34) 62 00-32
Internet: www.roxeler.de
E-Mail: mail@roxeler.de

Geschäftsführer: Diplom Ingenieure
Dr. Markus Johow, Dr. Stefan Kordtz,
Andre Liesenkötter
Amtsgericht Münster HR B 3320

Vereinigte Volksbank Münster eG
BIC: GENODEM1MSC
IBAN: DE15 4016 0050 1705 1576 00
UST-IdNr. DE 124376551